



**Underwriters  
Laboratories Inc.®**

**Melville Division**  
1285 Walt Whitman Road  
Melville, NY 11747-3081 USA  
www.ul.com  
tel: 1 631 271 6200  
fax: 1 631 271 8259

## CERTIFICATE OF COMPLIANCE

**CERTIFICATE NUMBER:** 20021212-E93565  
**ISSUE DATE:** 12.12.2002

**Issued to:** ABB SACE S.p.A  
VIA BAIONI 35  
24123 BERGAMO, ITALY

**Report Reference:** E93565


**This is to Certify that** Molded Case Circuit Breakers Types Tmax, T1, T2 and T3  
**representative samples of:**

**Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.**

**Standard(s) for Safety:** UL489, Standard for Molded Case Circuit Breakers, Molded Case Switches and Circuit Breaker Enclosures

**Additional Information:** These are one, two, three and four pole 40° C thermal magnetic circuit breakers with non-interchangeable trip units. These circuit breakers are intended as 100% rated when used in listed enclosures. When tripped, the handle takes an intermediate position between "On" and "Off".

**Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.**

The UL Listing Mark generally includes four elements as follows: the name "Underwriters Laboratories Inc." in various forms and type styles, or abbreviations such as "Und. Lab. Inc.", or the symbol "UL in a circle" - ; the word "Listed"; a control number (may be alphanumeric) assigned by UL; and the product or category name (product identifier), as indicated in the appropriate UL Directory.

**LOOK FOR THE UL CERTIFICATION MARK ON THE PRODUCT**

**Engineer:**

Mitchell Martin  
Underwriters Laboratories Inc.

**Review Engineer:**

Paul Notarian  
Underwriters Laboratories Inc.

An independent organization working for a safer world with integrity, precision and knowledge.

